

I think the design of the crossover will have to be carefully considered to avoid water from the carriageway flowing onto the site and contributing to the issues raised by the neighbours. This can be done by condition as previously advised. There is no indication on the plan of any SuDS features which may also help, but again this can be conditioned.

Best wishes

Steve Mountain
Civil Engineering Team Leader
Civil Engineering & Landscape Team
Havant Borough Council