

To Whom It May Concern:

The manufacturers official figures for the sound omitted from the environmental control plant equipment for the project at Ridgemount, Haccups Lane, SO51 0NP are listed below:

Linear Sound Power	Frequency	Fresh air	Exhaust air
<i>Lw dB :</i>	Hz		
	63	26.8	27.6
	125	25.9	27.2
	250	26.0	27.6
	500	25.4	27.2
	1000	25.2	27.2
	2000	24.9	26.7
	4000	22.8	24.3
	8000	19.0	20.3

These readings are taken within 3 metres from a unit with no ducting or sound attenuation attached.

This is the only piece of plant equipment producing sound clearly audible from the direct exterior of the plant room.

If you have any questions please call or email me.

Kind regards

Dominic Searle

Consultant
Aqua Platinum Projects

Mob: 07904 249565

Tel: 01489 896438

Email: dom@aquaplatinumprojects.co.uk

partners of   

**Unit 3, Lake View, Waltham Business Park, Swanmore,
Southampton, Hampshire, SO32 2SA**