

The Highway Authority has no adverse comment on this application subject to the proposed roller shutter door is conditioned to ensure that that it is not replaced with any other type of door that could overhang the highway. I would point out however that a double garage should be 6m wide by 5m deep. The 6m width is so to allow two cars parked in the garage to open their doors.

Peter J Marshall BSc MCIHT

Development Engineer
Havant Borough Council
Penner Road
Havant
Hants
PO9 1QH