

Michelle Houghton

From: David Eaves
Sent: 02 May 2014 11:05
To: bst shared
Subject: FW: 26 Leigh Road APP/14/00242 and APP/14/00244

Hi

Please add to Meridio and Web as Consultation Response Development Engineer

Thanks

David

From: Peter Marshall
Sent: 01 May 2014 16:25
To: David Eaves
Subject: RE: 26 Leigh Road APP/14/00242 and APP/14/00244

I have no adverse on this comment subject to a condition stating. The buildings shall not be re-occupied before the proposed access and the crossing of the highway verge and/or footway is constructed and laid out in accordance with details to be submitted to and approved in writing by the Local Planning Authority. These details shall include dropped kerb specifications, surfacing/edging materials and drainage to prevent discharge of water onto the highway. The access shall thereafter be constructed fully in accordance with the approved details.

Peter J Marshall BSc MCHIT
Development Engineer
Havant Borough Council
023 92446 457
Please note: I work Tuesday, Wednesday, Thursday