

Michelle Houghton

From: Michelle Good
Sent: 21 May 2015 14:56
To: bst shared
Cc: Richard Nash
Subject: FW: Acolaid Case APP/15/00420
Attachments: DocConsult04.pdf

Application No. APP/15/00420

Site Address: 9-11 St Georges Walk, Waterlooville, PO7 7TU

Proposed Development: Proposed construction of a building comprising 14 new apartments, 6 car parking spaces, a ground floor office, secure cycle store and secure accessible refuse stores following the demolition of No's 9 and 11 St Georges Walk, Waterlooville, PO7 7TU

Landscape Architect Response:

Further details are required for the proposed railings, hard landscape and soft landscape (anticipate this can this be addressed with planning conditions?).

Railings: Clarification of proposed height, detailed elevation / appearance, fixing method, material specification and colour
Paving: Material specification for block and edging, laying bond and colour
Planting: The planting area indicated is very limited in size, hence the suggested large shrub species are not appropriate. An alternative scheme comprising smaller species with some climbing plants (& supports) would be more appropriate. Further details regarding size specification, planting density and maintenance proposals are also required.

Kind Regards

Michelle Good CMLI
Senior Landscape Architect
Tel: 023 92446 537
<mailto:michelle.good@havant.gov.uk>

From: planning.development@havant.gov.uk [<mailto:planning.development@havant.gov.uk>]
Sent: 07 May 2015 13:50
To: Michelle Good
Subject: Acolaid Case APP/15/00420