

From: Coombe, Rebecca [<mailto:Rebecca.Coombe@environment-agency.gov.uk>] **On Behalf Of** PlanningSSD
Sent: 08 September 2015 14:11
To: Planning and Development Shared Mailbox
Cc: Havant Auto-Reply
Subject: Environment Agency response to Planning Application APP/15/00919

Dear Planning,

Thank you for consulting the Environment Agency on the above application.

The Environment Agency has no objection in terms of planning to the proposed development as submitted.

Ordinary Watercourse

The prior written consent of the relevant Lead Local Flood Authority is required for the erection of any flow control structures, culverting or diversion of ordinary watercourses, including streams, land drains and ditches.

Please be aware that the Lead Local Flood Authority has up to two months to determine applications for consent made under Section 23 of the Land Drainage Act 1991 and you are therefore advised to Hampshire County Council as soon as possible to discuss making an application.

Full details of HCC's consenting procedure and requirements can be found on [Hampshire CC Ordinary Watercourses](#). HCC's consenting email address is owc@hants.gov.uk

Regards,

Rebecca

Rebecca Coombe

Sustainable Places Advisor, Sustainable Places West, Environment Agency,
Romsey District Office, Canal Walk, Romsey, Hampshire, SO51 7LP