

**HAVANT BOROUGH COUNCIL**

**Town & Country Planning Act 1990**

**Consultation on Planning Application**

***MEMORANDUM***

|                              |                                                                                                                                                              |                  |                            |
|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|----------------------------|
| <b>From:</b>                 | <b>Environmental Health</b>                                                                                                                                  | <b>To:</b>       | <b>Development Control</b> |
| <b>Our Ref:</b>              | CONS/15/01736                                                                                                                                                | <b>Your Ref:</b> | APP/15/01225               |
| <b>EH Case Officer Extn:</b> | 44 6666                                                                                                                                                      | <b>Date:</b>     | 03 December 2015           |
| <b>DC Case Officer:</b>      | Daphney Haywood                                                                                                                                              |                  |                            |
| <b>DC Case Officer Extn:</b> | 44 6513                                                                                                                                                      |                  |                            |
| <b>Application Number:</b>   | APP/15/01225                                                                                                                                                 |                  |                            |
| <b>Site Address:</b>         | Langstone Technology Park, 2B Langstone Road, Havant, PO9 1SA                                                                                                |                  |                            |
| <b>Proposed Development:</b> | Installation of 2No. roof mounted condensor units and associated chiller pipe work to support 2No. additional internal computer room air conditioning units. |                  |                            |

---

**Observations / Comments:**

I refer to the above application under the Town & Country Planning Act, passed to this Service for comment.

I have read the enclosed documentation provided by the applicant and can comment as follows:

The noise report submitted by the consultant shows that the addition of these two units will not impact negatively on the existing background noise levels at the nearest sensitive residential properties, and that the pre-existing ambient noise levels in the area have been confirmed.

As such I have no further adverse comments to make on this application.

Should you have any queries in relation to the above, please do not hesitate to contact me.



**Mr. Mark Moss**

Regulatory Officer, Environmental Health