

From: Peter Marshall
Sent: 20 October 2015 15:29
To: David Eaves
Subject: FW: Acolaid Case APP/15/01094

The drive is very narrow at 3.35m but it already being used for access to the existing property so it is difficult to refuse the new property taking access from it.. I would like the drive widened at the entrance to at least 4.1m but would prefer 4.5 wide for ay 4,5 into the site to allow two cars to pass.

Peter J Marshall BSc MCIHT

Development Engineer
Havant Borough Council
Penner Road
Havant
Hants
PO9 1QH