



The Town and Country Planning Act 1990

Consultation on Planning Application

From : Executive Head of Planning and Built Environment

To: Building Control

DC Case Officer Mrs H Lealan Ext: 9244 6523

Date: 11 September 2015

Application No. APP/15/00930

Site Address: 48 Hart Plain Avenue, Waterlooville, PO8 8RX

Proposed Development: Proposed new single chalet bungalow to be constructed in the rear garden of no 48 Hart Plain Avenue. Replacement garage to be constructed at the front of the existing dwelling.

I attach a copy of the above application that has been received under the Town and Country Planning Acts.

Any views you should wish to make should be returned to me no later than 25 September 2015.

Andrew Biltcliffe

Andrew Biltcliffe
Executive Planning Service Manager

From: Building Control

The application has been examined under the following areas where Building Regulations may impact on the planning application. In achieving Building Regulation compliance there may be a number of design solutions available and until a Building Regulations submission has been made it is not always possible to advise what, if any, changes may be required to the design.

The following areas have been considered:

Fire Brigade Access† / Solid Waste Storage† / Glazing (Positions, quantities, cleaning)† /

Siting of building/structure† Building over public sewers† / Flues† / Other†

Please note no observations have been made in respect of disabled access. The DC Case Officer should discuss any access concerns with Building Control at the Access Surgery following assessment of the scheme using the access check sheet.

Observations:

- Consultation with HFRS should be carried out with regard to fire fighting access. Access road should be 3.7m wide and capable of carrying 12.5 tonnes. Consulted.

Signed: *AMR*

Dated: 14/9/15.