



HAMPSHIRE
FIRE AND
RESCUE
SERVICE



For the attention of Mr C Murray
Planning and Development
Havant Borough Council
Civic Offices
Civic Centre Road
Havant
Hampshire
PO9 2AX

Hampshire Fire and Rescue Service HQ
Business Fire Safety
Leigh Road
Eastleigh
Hampshire
SO50 9SJ

Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

Date: 10 November 2014

Enquiries To: Mr D Knight

My Reference: F6/DK/00826019

Your Reference: APP/14/01078

Dear Sir

Town & Country Planning Act 1990
Planning Application Number: APP/14/01078
48 Hart Plain Avenue, Waterlooville, PO8 8RX

I confirm that I have received a copy of your application dated 7 November 2014. One of my inspectors has considered the information provided and the following comments are made:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations.

Based on the plans provided access would appear not to meet these requirements in particular the load bearing of the access road is not detailed, the width of the proposed access road would appear unsuitable, the lack of a hammerhead or similar arrangement is noted.

The Fire Authority would be prepared to agree a compensatory feature such as a domestic sprinkler installation to allow use of the site.

If I can be of further assistance, please do not hesitate to contact me.

Continued

Any queries concerning these matters may be directed to the inspector named above but all correspondence should be addressed to me.

Please quote our reference number on all correspondence.

Yours faithfully

A handwritten signature in black ink, consisting of several fluid, overlapping strokes that form a stylized representation of the name.

for Chief Officer