

**Subject:** FW: Acolaid Case APP/15/00742

**Application No. APP/15/00742**

Site Address: Ben Hall, Hambledon Road, Waterloooville, PO7 6XB

Proposed Development: Discharge of Condition No's 3,4,5,6,7,14 and 16 of Planning Permission APP/14/01107.

I have reviewed the submitted proposals in consideration of conditions 4, 5 and 6

Condition 4 – Soft landscape

No adverse comments, hence I'm happy for this condition to be discharged

Condition 5 – Hard landscape

Additional information needs to be submitted to enable this condition to be discharged

Paving slab specification required (including product ref, colour, size dimensions, laying bond, edging & build-up detail)

Block paving specification requires clarification (Marshalls block? size dimensions, laying bond, edging & SUDS detail)

Condition 6 – fencing / boundary proposals

The following minor clarifications are required before this condition can be discharged

Proposed paint colour for frontage railings required

Extent of proposed close board fencing – please could this be emphasised more clearly on the drawing

Any queries, please don't hesitate to contact me.

Kind Regards

Michelle Good CMLI

Senior Landscape Architect

Tel: 023 92446 537