

From: Laurent Lemagnen
Sent: 09 September 2015 11:38
To: Richard Nash
Subject: RE: APP/15/00476 - 42 Bedhampton Hill, Havant

Good morning Richard,

Thank you for the info.
From the attachment I am happy that the noise should not be an issue

Thank you

I hope this helps

Kind regards

Laurent

Laurent Lemagnen
Regulatory Officer (Environmental Health)
Havant Borough Council
Direct line: 023 92 446671
Email: Laurent.lemagnen@havant.gov.uk

From: Richard Nash
Sent: 12 August 2015 08:06
To: Laurent Lemagnen
Subject: APP/15/00476 - 42 Bedhampton Hill, Havant

Hello Laurent

Thank you for your comments on the above planning application. The Applicant has now forwarded the attached and below, and is hopeful that your concerns could now be addressed by a planning condition if necessary. I have agreed an extension of time for determining the application, until 26 August, so it would be very helpful if you were able to comment further within the next week.

Thanks

Richard

Richard Nash
Principal Planning Officer
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
PO9 2AX

From: Peter Galloway - PGP Architects
Sent: 10 August 2015 12:05
To: Richard Nash
Subject: Fw: Pool @ Hill Lodge

Hi Richard

Following my e-mail last friday, please see attached which I am sure will be adequate to environmental health at this stage.

Peter Galloway

----- Original Message -----

From: [Dominic Searle](#)
To: [Peter Heather](#)
Cc:
Sent: Monday, August 10, 2015 10:31 AM
Subject: Re: Pool @ Hill Lodge

Morning Peter,

Following our discussion last week I can confirm that the means of sanitation that we would recommend for this pool would be chlorine and ozone or UV, which will be confirmed in our detailed design. I think it is most likely that ozone will be used.

This will be teamed with a sand filter of a suitable size to facilitate medium rate filtration.

With regard noise it is very hard to comment on the external noise of the plant equipment as there is no specification of air handling plant to work from. I have, however, attached a document pro ducted for a similar project with their AHU noise ratings which were submitted to planners and passed so I hope this helps.

Backwashing discharge into the mains drainage will be around 5l/s for up to 5 minutes once a week/fortnight.

Please let me know if you need anything further.

Kind regards,

Dominic Searle
Consultant

T. +44 (0) 1489 896438
M. +44 (0) 7904 249565
E. dom@aquaplatinumproject.co.uk
W. www.aquaplatinumproject.co.uk

WINNER of 2015 Outstanding Pool Design Award

• WINNER

**GRAND
DESIGNS
AWARDS 2014**



This email including attachments is confidential, may be covered by legal privilege. If you are prohibited from printing, copying or distributing it. If you have received this email in error, please delete the email from your system. Aqua Platinum Projects Limited. comp

From: Peter Heather
Date: Friday, 7 August 2015 16:20
To: Dominic Searle
Subject: Pool @ Hill Lodge

Dominic

Please see the attached.

Peter Galloway may not have attached this letter from the environment Officer.
Can you please review what he is asking for and advise accordingly?

Many thanks
Kind regards
Peter