

Brook Oak Tree Consultants Ltd
Laurel House
Burslem Road
Heathfield
East Sussex
TN21 8SS
Tel: 01435 862444
Email: brookoaktrees@connect.com

PURBROOK PARK SCHOOL
PARK AVENUE
PURBROOK
WATERLOOVILLE
HAMPSHIRE

TREE PROTECTION PLAN

T1 - T114 Tree numbers

BS Category of Condition

- T3 BS Condition A
- T1 BS Condition B
- T5 BS Condition C
- T2 BS Condition U

- Paced crown spread
- BS Calculated root protection areas
- Tree to be removed for safety
- Tree to be removed for development
- Protective fencing location
- Ground protection measures

TREE PROTECTION INFORMATION

Protective fencing measures to be installed at locations specified prior to commencement of any demolition works.

Protective fencing to comprise a scaffold framework with uprights driven into the ground to 60cm depth at no more than 3m spacing. Framework to be braced within high usage/construction/demolition areas. Weldmesh panels to be securely fixed to uprights to produce a continuous barrier. Waterproof signs to be attached to every 5th panel declaring "TREE ROOT PROTECTION ZONE - KEEP OUT" or similar wording. Fencing to be constructed in accordance with fig. 2 and section 6 Specifications of BS5837:2012.

Buildings in proximity to protected trees to be demolished by machinery pulling walls inwards onto the building footprint.

The fenced protection zones around retained trees, hedges and shrubbery are to be regarded as sacrosanct and none of the following are to occur within these areas:

- Storage or disposal of any soil, building materials, machinery, fuel or waste residues of any description.
- Siting of any temporary structures of any description including site office/soles buildings, temporary parking facilities, porta-loos, storage compounds or temporary hard standing areas.
- Excavations, soil/turf stripping, raising/lowering of existing levels or alterations to the existing natural surfaces/ground conditions of any other description.
- Location of temporary drainage, water supplies or any other temporary underground services.
- No use, movement or parking of any machinery or vehicles of any description.
- Additionally, no fires shall be lit within 20m of the trunks of any trees or the centre line of any hedgerow to be retained.

All services to be installed to the requirements of NAG Volume 4 "Guidelines for the Planning, Installation and Maintenance of Utility Apparatus in Proximity to Trees". Any runs within retained tree root protection areas to either be bored/moled or any hand excavation to be supervised by the Arboricultural Consultant.

DRAWING NO. J48.58/03 Rev B

Scale: 1:300 at A1

Added to by: NL

20/11/2014

