

Hi

These are offices to go on the patch of land by the Bedhampton railway gates that is too noisy etc for housing.

Please would you add as an informative to any comment you have (Jon/duty officer/NIT officer) that:-

This location, very close to the railway, has problems from noise and vibration. Windows will need acoustic double glazing (with associated acoustic ventilation) to reach acceptable levels for an office. In addition some sensitive equipment could be affected by the vibrations of the trains. Anti-vibration measures could be designed in at the construction stage.

Lorna Read
Environmental Health Team Leader (Commercial)
Havant Borough Council
Public Service Plaza
Havant
Hants
PO9 2AX
02392 446665