



HAMPSHIRE
FIRE AND
RESCUE
SERVICE

HAVANT BOROUGH
COUNCIL

10 DEC 2014

RECEIVED

For the attention of Ms D Haywood

Chief Building Control Officer

Havant Borough Council

Civic Offices

Civic Centre Road

HAVANT

Hampshire

PO9 2AX

Hampshire Fire and Rescue Service HQ

Business Fire Safety

Leigh Road

Eastleigh

Hampshire

SO50 9SJ

Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

No BC App.

Assumed DC App 14/0625

MR

Date: 08 December 2014

Enquiries To: Mr D Knight

My Reference: F6/DK/00826098

Your reference: App/14/0116

Dear Sir

Town & Country Planning Act 1990

Planning Application Number: App/14/0116

16 Latchmore Forest Grove, Waterloo, PO8 8XG

I confirm that I have received a copy of your application dated 04 December 2014. One of my inspectors has considered the information provided and the following comments are made:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations. With the information provided it is not possible to determine this. If suitable access is not provided a compensatory feature such as an Automatic Water suppression System should be agreed with the Fire Authority.

If I can be of further assistance, please do not hesitate to contact me.

Any queries concerning these matters may be directed to the inspector named above but all correspondence should be addressed to me.

Please quote our reference number on all correspondence.

Yours faithfully

for Chief Officer

MR: 033 V: 0.3

