




Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/15/00586

Our Ref

PLAN-0010045

Date

25/06/2015

Dear Sir

**Proposal: Discharge of Condition No/s 5, 6, 7, 10, 12, 13, 15, 16 and 18 of
Planning Permission APP/14/01300.**

**Site: Premier Inn, Langstone Technology Park, 2B Langstone Road, Havant,
PO9 1SA.**

APP/15/00586

Thank you for your letter of 05/06/2015

Southern Water cannot discharge condition relating to foul drainage due to the proposal to discharge treated flows to the foul sewer. Treated flows for the grey water treatment plant should not be connected to the public foul sewer. Over flows from the grey water (untreated) could be connected to the public sewerage system. Approval for the connection should be submitted under a section 106 connection application.

The Council's Building Control officers/technical staff and the environment agency should be consulted regarding the discharge condition for surface water disposal.

Yours sincerely

Developer Services