

Landscape Architect Response

Application No. APP.13.000366

Development: 132 Havant Road- reinstatement of hedge

Case Officer: D Eaves

Comments by: L. Gilbertson

Date of Comments: Nov 8th 2013

Observation/ Comments:

A better plan with more information is required, and some amendments are required:

We would like some larger specimens amongst the hedge mix – would suggest some 8-10 cm girth field maples to create immediate impact and structure. Include 1 for every 10 metres or so- around 8 along this length should be sufficient.

Include some smaller field maples also in the remaining mix and please indicate the proportion of and numbers of the rest of the plants to be planted.

The Havant Landscape Character Assessment can be found at

<http://www-old.havant.gov.uk/havant-7364>

See the Hampshire Landscape checklist :

<http://www.hiow.gov.uk/offnet/hlg/47340%20Oce%20Checklist.pdf>

Havant
BOROUGH COUNCIL