

Subject: RE: Emailing: GetDocumentContent - APP/15/00586 - Premier Inn, Havant (13097)

Mark,

Further to the letter from Southern Water dated 25th June 2015, we would like to respond to the queries raised as below.

The attached drawing "*13097:01E Engineering Layout*" illustrates that the grey water tank has an overflow pipe that connects into the proposed foul water system. The overflow from the grey water tank is from the incoming chamber of the system, prior to any of the filtering stages. Therefore, the flows passing through the overflow pipe would be the same as the foul water flows which enter into the grey water tank.

In addition, please find attached the S106 Sewer Connection Approval which confirms that Southern Water are happy for this development to connect to the public foul water sewer, as per the drainage scheme shown on our drawing "*13097:01E Engineering Layout*".

To reiterate, it is proposed to discharge untreated flows from the grey water tank via the overflow pipe to the public foul water sewer, in accordance with the S106 Sewer Connection Approval provided by Southern Water. Therefore, we would deem that the overflow from the Grey Water Tank into the foul water system should not impede the discharge of the associates planning conditions.

If you have any queries, or require any further information, please feel free to contact myself.

Regards

James Cook
Simpson Associates
Tel: 01491 576 221