

From: Peter Marshall
Sent: 04 September 2014 16:34
To: David Eaves
Subject: FW: Acolaid Case APP/14/00802

I have no adverse comment on this application subject to the following condition.
the existing dropped kerb in the middle of the s reinstated to footway
the existing dropped kerb to the west of the site is increased in width.
each plot has two parking spaces and cycle facilities
each plot has turning provide and kept to allow vehicles to turn on site and exit in a forward gear.

Peter J Marshall BSc MCHIT
Development Engineer
Havant Borough Council
023 92446 457
Please note: I work Tuesday, Wednesday, Thursday