

Acolaid Case APP/15/00509

Formal Response

The Highway Authority have no adverse comment to this application.

My advice to the planning Authority is that the application includes a parking plan which shows four parking spaces one car behind each other which is not practical.

The HBC parking standard is 3 spaces for a three bed property.

Peter J Marshall BSc MCIHT

Development Engineer
Havant Borough Council
Penner Road
Havant
Hants
PO9 1QH