| Luminaire Schedule | | | | | | |
|---|---|---|---|---|---|---|
| Symbol | Qty | Label | Arrangement | Total Lamp Lumens | LLF | Description |
| | 28 | EX1 | SINGLE | 6800 | 0.760 | 96259469 CIVIC 1 70W HST DGE CL1 ESH PN RES/L (V4L4) |

| Calculation Summary | | | | | | | |
|---|---|---|---|---|---|---|---|
| Label | CalcType | Units | Avg | Max | Min | Min/Avg | Min/Max |
| Car Parking | Illuminance | Lux | 13.76 | 22 | 4 | 0.29 | 0.18 |
| Car Parking_1 | Illuminance | Lux | 9.59 | 21 | 3 | 0.31 | 0.14 |
| Car Parking_2 | Illuminance | Lux | 8.98 | 22 | 1 | 0.11 | 0.05 |
| Grid 1 - Roadway | Illuminance | Lux | 10.10 | 24 | 2 | 0.20 | 0.08 |
| Grid 2 - Pathway | Illuminance | Lux | 9.84 | 22 | 2 | 0.20 | 0.09 |

**Notes**

# For Information Only

Not to be used for Construction

Construction Design & Management (CDM) Regulations:
The proposed lighting scheme and this supporting documentation has been designed on the basis of the information provided by the client's brief. The client should ask the installer for maintenance and safety information where required under CDM regulations. Thorn Lighting Limited or its staff have not carried out a CDM risk assessment of this design.

Lighting calculations have been performed according to SLL or ILE standards and good design practice. Some difference between measured values and those calculated may occur due to calculation methods, testing procedures, component performance, field conditions and assumptions made by the design team/client, e.g. room surface reflectance. Such differences may typically be ±10%. Emergency lighting calculations are only indicative and thus no liability for non-performance will be accepted.
The information presented here is for guidance only and Thorn Lighting Ltd accept no liability for non-performance or subsequent use of this information. This drawing has been issued for consideration only, and does not constitute a contract in any form.

| No. | Date | Revision |
|---|---|---|

Title:
Ranelagh Road
Havant Hants

Area:
Hants

Client:

Drawn by:
EB

Checked by:
-

Scale:
1:500 @ A1

Revision:
01

Project/Lizard Ref.:
LIZ0128358

Date:
06/05/14

Drawing Number:
TLL/S/0128358/EX/R1/050614

Drawing Status:
FOR APPROVAL


Thorn Lighting Limited
Durhamgate
Spennymoor
Co. Durham
DL16 6HL

Tel: 01388 420042
Fax: 01388 420156
www.thornlighting.co.uk


THORN


Copyright in this drawing is the property of Thorn Lighting Limited. It must not be reproduced nor amended without the written consent of Thorn Lighting Limited. Do not scale from this drawing.