



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/14/00488

Our Ref

PLAN-006690

Date

01/07/2014

Dear Sir

Proposal: Reserved matters application for 131No. open market and affordable dwellings including 10No. one bed dwellings, 25No. two bed dwellings, 52No. three bed dwellings, 40No. four bed dwellings and 4No five bed dwellings with associated residential curtilages, parking and turning areas, public open space and surface water attenuation features; and discharge of conditions 5, 6, 10, 15 and 21 of Planning Permission APP/14/00966 approved by appeal APP/X1735/A/13/2192777.

Site: Development Site North of, Goldring Close, Hayling Island, PO11 9PN. APP/14/00488


Thank you for your letter of 18/06/2014

Southern Water has no comments to make in respect of the above condition application submitted.

The comments in our original response dated 18/10/2012 remain unchanged and valid.

Yours faithfully

Developer Services



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your Ref
APP/12/00966
Our Ref
H/HA/2012/00966
Date
18/10/2012

Dear Sir

Proposal: Outline application for 131 open market and affordable dwellings comprising 10No 1bed flats, 4No 2bed flats, 48No 2bed houses, 49No 3bed houses, 20No 4 bed houses; public open space; car parking; new vehicular access.

Site: Land North of Goldring Close and My Lords Lane, East of St Margarets Road and South of Beech Grove and Hawthorne Grove, Hayling Island PO119ET. APP/12/00966

Thank you for your letter of 01/10/2012.

Please find attached a plan of the sewer records showing the approximate position of a public rising main crossing the site. The exact position of the public rising main must be determined on site by the applicant before the layout of the proposed development is finalised.

It might be possible to divert the public rising main, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

Should the applicant wish to divert apparatus:

1. The 400 mm rising main requires a clearance of 3 metres either side of the sewer to protect it from construction works and allow for future access for maintenance.
2. No development or new tree planting should be located within 3 metres either side of the centreline of the public rising main.
3. No new soakaways should be located within 5 metres of a public rising main.
4. All other existing infrastructure should be protected during the course of construction works.

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items (1) – (4) above also apply.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example "The developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to divert the public sewers, prior to the commencement of the development."

Furthermore, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688).

Following initial investigations, there is currently inadequate capacity in the local network to provide foul sewage disposal to service the proposed development. The proposed development would increase flows to the public sewerage system, and existing properties and land may be subject to a greater risk of flooding as a result. Additional off-site sewers, or improvements to existing sewers, will be required to provide sufficient capacity to service the development. Section 98 of the Water Industry Act 1991 provides a legal mechanism through which the appropriate infrastructure can be requested (by the developer) and provided to drain to a specific location.

Should this application receive planning approval, please include, as an informative to the permission, the following requirement:


"The applicant/developer should enter into a formal agreement with Southern Water to provide the necessary sewerage infrastructure required to service this development. Please contact *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688), or www.southernwater.co.uk*".

The planning application form makes reference to drainage using Sustainable Urban Drainage Systems (SUDS).

Under current legislation and guidance SUDS rely upon facilities which are not adoptable by sewerage undertakers. Therefore, the applicant will need to ensure that arrangements exist for the long term maintenance of the SUDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system.

Thus, where a SUDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

- Specify the responsibilities of each party for the implementation of the SUDS scheme
- Specify a timetable for implementation



- Provide a management and maintenance plan for the lifetime of the development.

This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

Yours faithfully

Developer Services

SOUTHERN WATER

HAVANT BOROUGH
COUNCIL

- 3 JUL 2012

RECEIVED



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SZ7299NE

Scale: 1:2500

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

 Southern
Water

Printed By: banuh

Date: 18-10-2012

Southern Water MapGuide Browser

Requested By:

