

Denise Sheath

From: Tracey Ford
Sent: 24 June 2014 11:30
To: Planning and Development Shared Mailbox
Cc: Peter Marshall
Subject: APP/14/00587 19-30 Renown Gardens Waterloooville

Highway comments

The parking places must meet the minimum 4.8m depth back from footway when construction is completed. A construction management plan detailing the details of displaced car parking during construction, material storage/construction site office/accommodation, construction vehicle parking and any footway access during construction will be maintained.

Regards
Tracey

Tracey Ford

Sustainable Transport Engineer
Havant Borough Council
Southmoor Office and Depot
2 Penner Road
Havant
Hampshire
PO9 1QH

Tel 023 92446210
Fax 023 92498031

[MAP](#)

[PLAN YOUR CYCLE JOURNEY HERE](#)