

Michelle Houghton

From: Daphney Haywood
Sent: 05 February 2014 09:44
To: bst shared
Subject: FW: APP/14/00030 14 The Briars, Waterberry Drive, Waterlooville, - Env Health response for meridio and web

From: Laurent Lemagnen
Sent: 04 February 2014 10:06
To: Daphney Haywood
Subject: APP/14/00030 14 The Briars, Waterberry Drive, Waterlooville, PO7 7YH

Good morning Daphney.

I had a look at the application to install AC at the above address.

I would like for condition relating to acoustical report to be submitted prior commenting. I have seen the acoustical outputs of the machine, but this does not put it into context in relation to the local environment or the potential for disturbance.

The report should follow the guideline on reporting from BS4142. Until such report is received, I would like to refuse the application on noise ground. Should the Planning Authority be minded to grant this application I would like the following condition to be inserted.

1. Noise generated from the condenser units and other equipments.

Condition 1: Any proposal relating to install noise making equipment (i.e. refrigeration units, air conditioning, extract ventilation equipments) schemes shall be agreed and approved in writing by the District Planning Authority prior any development takes place.

Reason: To protect the occupants of nearby residential properties from noise, vibration and/or odour nuisance.

BS4142 Requirement

Noise resulting from the use of any/all plant, machinery or equipment shall not exceed a level of 5dB(A) below the existing background level (or 10dB(A) below if there is a particular tonal quality) when measured according to British Standard BS4142-1997.

Reason: in the interests of protecting the local residents from unreasonable noise levels which would be detrimental to the residential character of the area.

I hope this helps

kind regards
Laurent

Mr. L. Lemagnen
Senior Environmental Health Officer
Tel: 02392 446671
Email: laurent.lemagnen@havant.gov.uk
Address: The Plaza, Civic Centre Road, Havant, Hampshire, PO9 2AX