

Alex Webb

Subject: Discharge of conditions - APP/14/00008 - Former Bedhampton Arts Centre, 29 Bedhampton Road, Havant
Attachments: R5011-2 Rev 0 Bedhampton.pdf

From: Steve Gosling [<mailto:Steve@24acoustics.co.uk>]

Sent: 14 May 2014 14:57

To: Alex Webb

Cc: grahamparrett@hotmail.com

Subject: RE: Discharge of conditions - APP/14/00008 - Former Bedhampton Arts Centre, 29 Bedhampton Road, Havant

Alex,

I can confirm that the specification of the 1.8m acoustic fence should have a minimum superficial weight of 12 kg/m² and not contain any holes or openings. I can confirm also that this is an addendum to our technical report R5011-2 Rev 0 (also attached).

Trust this is OK - happy to discuss.

Regards,

Steve

office - 01794 515999

mobile - 07976 257725