



Faraj Arfa-Zangeneh
Caulmert Ltd
Cattermole Building
Market Place
Codnor
Derbyshire
DE5 9QA

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

10/10/2014

Our Ref: SWS-HANTS-S106-006326

Application to Connect to the Public Sewerage System - Section 106 Water Industry Act 1991

Location: Purbrook Park School, Park Avenue, Purbrook, Waterlooville, Hampshire, PO7 5DS.

Dear Mr. Zangeneh,

Further to your recent application to connect to the public sewerage system at the above location. I am pleased to inform you that your proposal to connect to the surface water sewers via an existing manhole has been approved subject to the following provision:-

Connections to existing manholes and arrangement of pipe junctions within the manhole should be in accordance with Sewers for Adoption 7th edition and Southern Water guidance documentation.

Please contact Mick Vince our Clerk of works for this area on 07803 259227 giving at least 2 full working days notice, in order that a mutually convenient date and time for the inspection of the works can be arranged.

If connection is to be made through the lands of another, the works may not proceed until the Landowners consent has been obtained.

In approving this application it is assumed that you have obtained any necessary Building Regulations Approval and /or Highway Authority Road Opening License.

Yours sincerely,

 Developer Services