

From: Laurent Lemagnen
Sent: 08 April 2015 10:38
To: Tina Pickup
Subject: RE: Acolaid Case CONS/15/00417

Good morning Tina,

I have been to the location and assessed the proposal and the area. I have spoken to Mr Turner and from our conversation and what he intend to do at the site should not negatively impact on residential properties to the East and West and have a minimal impact (if any) on businesses within the complex. I therefore **have no objection to this application.**

The music proposed to be played within the unit will be played no louder than background so that instruction can be given to the users of the site. Due to the thermal insulation currently present, Mr Turner informed that the need for A/C should not be required. If possible, Would it be possible to add a condition saying that "should A/C or other equipment be necessary to cool/heat the air within the unit (apart from normal central heating), a planning application should be sought and granted prior to installing such equipment"?

However, in order to ensure minimal effect, the unit would need to have plaster boarding to the ceiling (throughout) and the walls (south). Rubber matting as discussed during our meeting should be installed throughout the site in order to minimise impact noise and also to serve as a noise absorber. Doors and windows, shall be kept close when the music is being played at all times.

I hope this helps

Kind regards

Laurent

Laurent Lemagnen
Regulatory Officer (Environmental Health)
Havant Borough Council
Direct line: 023 92 446671
Email: Laurent.lemagnen@havant.gov.uk