

From: Peter Marshall
Sent: 21 May 2014 10:40
To: Daphney Haywood
Subject: FW: Acolaid Case APP/14/00463

In principle I have no objection to this application providing it is used as part of the existing dwelling. However the plan showing the parking layout does not work, a car needs a minimum of 6 metres to reverse out of a space and this appears not to be achievable. I would suggest a new plan is submitted showing practical parking and turning on site.

Peter J Marshall BSc MCHIT
Development Engineer
Havant Borough Council
023 92446 457
Please note: I work Tuesday, Wednesday, Thursday