



Mr Mike Ellwood
Speltham Contracts Ltd.

Developer Services
Southern Water
Sparrowgrove House
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Our Ref: SIM001

Date: 10 September 2014

Dear Mr Ellwood

Re: sewer trace – 26A Birch Tree Drive Westbourne.

Please find attached a copy of a plan confirming the actual position of our sewer in relation to the above address.

As the sewer is north of the fence line, 375mm in diameter and 1m deep, we can advise that no new construction should be undertaken within 2m of the fence line within the boundary of 26a Birch Drive.

Please note that the content of this letter is for information only and does not replace any formal application required in regard to any proposed construction to be undertaken on the site.

Yours sincerely

A handwritten signature in black ink, appearing to read "JBenn", with a long horizontal flourish extending to the right.

Jeanette Benn
Customer Services Manager

26A Birch Tree Drive Westbourne.

