



HAMPSHIRE
FIRE AND
RESCUE
SERVICE

Planning and Development
Havant Borough Council
Civic Offices
Civic Centre Road
Havant
Hampshire
PO9 2AX



Hampshire Fire and Rescue Service
Business Fire Safety
Leigh Road
Eastleigh
Hampshire
SO50 9SJ

Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

Date: 26 June 2014

Enquiries To: Mr D Knight

My Reference: F6/DK/00813151

Your Reference: APP/14/00439

Dear Sir

Town & Country Planning Act 1990

Planning Application Number: APP/14/00439

Land rear of 109 London Road, Waterloooville, PO8 8XJ

I confirm that I have now received a revised copy of the application dated 25 June 2014. One of my inspectors has considered the information provided and the following comments are made:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations or a suitable compensatory provision agreed with the Fire Authority.

The tracking drawing provided does not give details of the load bearing of the access route or details of how issues such as parking can be managed to ensure access for emergency service vehicles.

If I can be of further assistance, please do not hesitate to contact me. Any queries concerning these matters may be directed to the inspector named above but all correspondence should be addressed to me.

Please quote our reference number on all correspondence. Please send all future correspondence to the address at the to of this letter.

Yours faithfully

For Chief Officer

MR: 033 V: 0.3

