

Michelle Houghton

From: Steve Weaver
Sent: 06 May 2014 15:27
To: bst shared
Subject: FW: Acolaid Case APP/14/00256 - 183 Southwood Road, Hayling Island, PO11 9PZ
Attachments: DocConsult04.pdf

Please could you import this consultation response to case APP/14/00256 and publish on the web.

Thanks

Weave

Steve Weaver
Development Control Team Leader

Havant Borough Council
Public Service Plaza
Havant PO9 2AX

Direct Dial Telephone Number (023) 9244 6512
email: steve.weaver@havant.gov.uk
Website: www.havant.gov.uk

From: Peter Marshall
Sent: 25 March 2014 12:08
To: Steve Weaver
Subject: FW: Acolaid Case APP/14/00256 - 183 Southwood Road, Hayling Island, PO11 9PZ

In principle it is acceptable to increase the number of garages but a standard garage is 3 metres by 6 m so the garage block should be 15m by 6m. The existing three garages are to the old standard so it does not seem unreasonable to allow this application. However if the number of new garages is not an important criteria I would suggest that only 4 garages are built to the current standard (or larger at 3.6m wide) which would allow a driver to easily open the doors of a modern car within the garage!

Peter J Marshall BSc MCHIT
Development Engineer
Havant Borough Council
023 92446 457
Please note: I work Tuesday, Wednesday, Thursday

From: planning.development@havant.gov.uk [<mailto:planning.development@havant.gov.uk>]
Sent: 21 March 2014 09:40
To: Peter Marshall
Subject: Acolaid Case APP/14/00256