

Richard,

The drawing does not show if it a dropped kerb or bellmouth and it is very difficult to scale. The plan also shows gate which will need to be set back 5 metres from the edge of the highway. Also the access needs to be a minimum of 4.1 to allow vehicles to pass. I would suggest that we have a condition that the design of the "entrance and access" to the site has to be agreed in writing

Regards Pip

Peter J Marshall BSc MCIHT

Development Engineer

Havant Borough Council