

From: Les Glass

Sent: 08 April 2014 10:51

To: Sally Smith DC

Subject: RE: APP/14/00232 Development site at Portsdown Hill, Wst. of Glebe Pk Ave

Sally

We wont need a condition as the properties will have to have double glazing with trickle vents to comply with Building Regulation requirements. We would only need a condition if a higher specification glazing unit than a 4 : 6-20 : 4 unit was required (which it isn't).

Les

Les Glass

Environmental Health Team Leader (Environment)

Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
PO9 2AX

Tel. (023) 9244 6668

www.havant.gov.uk