

From: Peter Marshall
Sent: 12 March 2014 15:19
To: Sally Smith DC
Subject: FW: Acolaid Case APP/14/00232

Sally I think it is important that we ask for overlays showing that each of the residential units can be assessed by refuse freighters and also overlays to show they comply with the 45m building reg with regard to fire access (although they could have sprinklers installed which negates this requirement). I will get back on the other points once I have examined all the detail.

Peter J Marshall BSc MCHIT
Development Engineer
Havant Borough Council
023 92446 457
Please note: I work Tuesday, Wednesday, Thursday