



**HAMPSHIRE
FIRE AND
RESCUE
SERVICE**

For the attention of Mr C Murray
Planning Development
Havant Council
Public Service Plaza
Civic Centre Road
Havant
PO9 2AX



Hampshire Fire and Rescue Service HQ
Business Fire Safety
Leigh Road
Eastleigh
Hampshire
SO50 9SJ

Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

Date: 11 September 2014

Enquiries To: Mr D Knight

My Reference: F6/DK/00825812

Your Reference: APP/14/00862

Dear Sir

Town & Country Planning Act 1990

Planning Application Number: APP/14/00862

Land bounded by Solent Road, Brockhampton Lane and Selbourne Road, Havant

I confirm that I have received a copy of your application dated 10 September 2014. One of my inspectors has considered the information provided and the following comments are made:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations. This is not clear from the plans provided.

Water Supplies

Additional water supplies for fire fighting may be necessary. You should contact the Community Response Support, Hampshire Fire and Rescue Headquarters, Leigh Road, Eastleigh, SO50 9SJ (risk.information@hantsfire.gov.uk) to discuss your proposals.


If I can be of further assistance, please do not hesitate to contact me.

Continued

Any queries concerning these matters may be directed to the inspector named above but all correspondence should be addressed to me.

Please quote our reference number on all correspondence.

Yours faithfully

A handwritten signature in black ink, consisting of several fluid, overlapping strokes that form a stylized, cursive-like name.

for Chief Officer