



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/14/00772

Our Ref

PLAN-007080

Date

14/08/2014

Dear Sir

Proposal: Conservatory to rear of property.

Site: 118 Havant Road, Hayling Island, PO11 0LJ.

APP/14/00772

Thank you for your letter of 04/08/2014

Southern Water has no objections to the above proposal.

Please note there is 150 mm diameter BAC foul sewer within the site.

-No new tree planting should be located within 3 metres either side of the centreline of the public foul sewer and all existing infrastructure should be protected during the course of construction works and

-No new soakaways should be located within 5 metres of a public foul sewer.

Yours sincerely

Developer Services

SOUTHERN WATER

HAVANT BO. COUNCIL

19 AUG 2014

RECEIVED

Stoke

Track

The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU7102NE

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

Southern Water

Printed By: jayarar

Date: 14-8-2014

Southern Water MapGuide Browser

Requested By:

