

SSL WATERLOOVILLE ROOF MOUNTED ATTENUATORS

Equipment Noise Data Schedule

Project: Sainsbury, Waterloooville

Date: 10/09/2014

Ref.	Description	Noise Data Source	Vol (m³/s)	Total Static Pressure (Pa)	Octave band mid frequency (Hz)							Noise Data Type	DIMENSIONS OF EXTERNAL ATS
					63	125	250	500	1k	2k	4k	8k	
ATT1GM	AHU1GM SUPPLY	Manufacturer	4.88	0	74	79	81	86	83	81	73	72	1050 x 1050 x 1500
ATT1SA	AHU1SA EXTRACT	Manufacturer	11.40	0	79	90	86	85	85	83	75	79	1300 x 1000 x 1800
ATT2SA	AHU1SA SUPPLY	Manufacturer	11.40	0	83	93	94	94	92	90	78	80	(300) x 1000 x 1800
ATT1D	AHU1D SUPPLY	Manufacturer	1.10	0	70	79	77	76	78	73	71	67	
ATT2D	AHU1D FAI	Manufacturer	1.10	0	66	64	72	71	67	68	66	64	

✗ EXTERNALLY LOCATED IN PLANT WELL