

Michelle Houghton

From: Stephen Andrews
Sent: 25 April 2014 10:58
To: bst shared
Subject: FW: Acolaid Case APP/14/00329

Please can you link this consultation response to Meridio?

Many thanks

Stephen

From: Louise Gilbertson
Sent: 09 April 2014 14:51
To: Stephen Andrews
Subject: FW: Acolaid Case APP/14/00329

Kind Regards

Louise Gilbertson CMLi
Landscape Architect
Tel: 023 92446 537 Fax: 023 9249 8031

From: Louise Gilbertson
Sent: 09 April 2014 14:50
To: Stephen Andrews
Subject: FW: Acolaid Case APP/14/00329

Hi Stephen

There aren't any landscape details on the drawing supplied. - no plant names or numbers supplied?
I see in the letter and on the drawing they reference 'alpine plants'-we need details to assess suitability - this is likely to be quite a shady area as it is surrounded by existing and the new development. It requires a sensible plan with the correct planting to be a success.

Additionally there are parts of this site that could cope with something a little more substantial than just ground cover and it would benefit to soften the scheme and add planting to help the scheme sit within the existing environment better.

The hard landscaping is suitable, however an edging restraint needs to be provided to all paved areas - nothing has been shown or specified. An edge between different types of surfacing and edging to the shrub beds will be required.

I await further details.

Please refer the applicant towards the Hampshire Landscape checklist :
<http://www.hiow.gov.uk/offnet/hlg/47340%20Oce%20Checklist.pdf>

The Havant Landscape Character Assessment can be found at
<http://www-old.havant.gov.uk/havant-7364>

Kind Regards

Louise Gilbertson CMLi
Landscape Architect
Tel: 023 92446 537 Fax: 023 9249 8031

From: planning.development@havant.gov.uk [<mailto:planning.development@havant.gov.uk>]
Sent: 26 March 2014 16:10
To: Louise Gilbertson
Subject: Acolaid Case APP/14/00329



DocConsult04.pdf