



**HAMPSHIRE
FIRE AND
RESCUE
SERVICE**

For the attention of Mr C Murray
Service Manager Planning Development
Public Service Plaza
Civic Centre Road
Havant
PO9 2AX

Hampshire Fire and Rescue Service HQ
Business Fire Safety
Leigh Road
Eastleigh
Hampshire
SO50 9SJ



Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

Date: 07 October 2014

Enquiries To: Mr V Martin

My Reference: F6/VM/00816438

Your Reference: APP/14/00995

Dear Sir

Town & Country Planning Act 1990

Planning Application Number: APP/14/00995

Renewal for Planning, Street Market, West Street Precinct, Havant, Hampshire

I confirm that I have received a copy of your application dated 6 October 2014. One of my inspectors has considered the information provided and the following comments are made:

These comments are made in connection with the Regulatory Reform (Fire Safety) Order 2005 And form part of The Town and Country Planning Act 1990 application.

Compliance with the Regulatory Reform (Fire Safety) Order 2005

Fire exit routes from adjacent premises and access to services such as Fire Hydrants and shut off points for gas electric and water services should not be obstructed.

Part B5: Access and Facilities for the Fire Service

The access for fire appliances should be in accordance with Approved Document B5 of the current Building Regulations.

Yours faithfully

for Chief Officer

MR: 033 V: 0.3

