




HAMPSHIRE
FIRE AND
RESCUE
SERVICE

For the attention of Ms D Haywood

Planning Services
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Hampshire Fire and Rescue Service
Service Delivery (Community Safety Delivery)
Protection Department
Southsea Fire Station
Somers Road
Southsea
Hampshire
PO5 4LU



Tel: 02392 855180

Fax: 02392 855175

Email: csprotection.admin@hantsfire.gov.uk

Date: 11 February 2014

Enquiries To: Mr V Martin

My Reference: F6/VCM/LA/00824982

Your Reference: APP/13/00804/Woodcroft

Dear Daphney

Town & Country Planning Act 1990

Planning Application Number: APP/13/00804/Woodcroft

Woodcroft Farm Development Site, Woodcroft Lane, Waterlooville

I confirm that I have received a copy of your application dated 30 January 2014. One of my inspectors has considered the information provided and the following comments are made:

Hampshire Act 1983 Section 12 - Access for Fire Service

Access **to** the proposed site should be in accordance with Hampshire Act 1983 Sect, 12 (Access to buildings **within the site** will be dealt with as part of the building regulations application at a later stage). Access roads **to** the site should be in accordance with Approved Document B5 of the current Building Regulations.

Water Supplies

Additional water supplies for fire fighting may be necessary. You should contact the Community Response Support, Hampshire Fire and Rescue Headquarters, Leigh Road, Eastleigh, SO50 9SJ (risk.information@hantsfire.gov.uk) to discuss your proposals.

Continued

If I can be of further assistance, please do not hesitate to contact me.

Any queries concerning these matters may be directed to the inspector named above but all correspondence should be addressed to me.

Please quote our reference number on all correspondence.

Yours faithfully

A handwritten signature in black ink, consisting of a stylized 'J' or 'I' followed by a horizontal line.

for Chief Officer

