



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/14/00796

Our Ref

PLAN-007078

Date

14/08/2014

Dear Sir

Proposal: Single storey side conservatory.

Site: 16 Oakmount Drive, Waterlooville, PO8 8TH.

APP/14/00796

Thank you for your letter of 04/08/2014.

Southern Water has no objections to the above proposal.

Please note 1350mm foul sewer within the site.

-No new tree planting should be located within 5 metres either side of the centreline of the public foul sewer and all existing infrastructure should be protected during the course of construction works and

-No new soakaways should be located within 5 metres of a public foul sewer.

Yours sincerely

Developer Services

HAVANT COUNCIL
19 AUG 2014
RECEIVED



Southern Water

Requested By:

