

Surface Water Drainage: the outfall from the pumped main at Washington Road should be into the head of the open ditch, not into the connecting culvert which it meets at an acute angle (drawing 14776-65).

Foul Water Drainage: consent from southern Water required for connection to public sewer in North Street (drawing 14776-67).

Best wishes

Steve Mountain
Special Projects Engineer
Transport & Implementation Team
Environment & Neighbourhood Quality
Havant Borough Council
Southmoor Offices and Depot, 2 Penner Road, Havant, PO9 1QH
[\[Location Map\]](#) [\[Get here by bike \(journey planner\)\]](#) [\[Get here by bus \(journey planner\)\]](#)
[\[For a more sociable way of travelling, why not Car Share?\]](#)

Telephone: 023 9244 6444
Fax: 023 9249 8031
HBC on the web: www.havant.gov.uk