

Havant Borough Council

The Town and Country Planning Act 1990

Consultation on Planning Application

From : Executive Head of Planning and Built Environment

To: Building Control

DC Case Officer Mrs T Pickup Ext: 9244 6461

Date: 02 July 2014

Application No. APP/14/00612

Site Address: Waterlooville Swimming Pool, Waterberry Drive, Waterlooville, PO7 7UW

Proposed Development: Variation of Condition 8 of Planning Permission APP/14/00023 to change the required BREEAM rating from 'Very Good' to 'Good'.

I attach a copy of the above application that has been received under the Town and Country Planning Acts.

Any views you should wish to make should be returned to me no later than 16 July 2014.



Mr Chris Murray
Service Manager (Planning Development)

From: Building Control

The application has been examined under the following areas where Building Regulations may impact on the planning application. In achieving Building Regulation compliance there may be a number of design solutions available and until a Building Regulations submission has been made it is not always possible to advise what, if any, changes may be required to the design.

The following areas have been considered:

Fire Brigade Access† Solid Waste Storage† Glazing (Positions, quantities, cleaning)†

Siting of building/structure† Building over public sewers† Flues† Other†

Please note no observations have been made in respect of disabled access. The DC Case Officer should discuss any access concerns with Building Control at the Access Surgery following assessment of the scheme using the access check sheet.

Observations:

No comment

Signed:



Dated:

2/7/14