

From: Mark Moss
Sent: 17 January 2014 17:15
To: Jenna Shore
Subject: App/13/01180 - 38-40 Greywell Road - amusement centre

Good day Jenna

In response to the Acoustic testing report submitted for the above property, I can advise the following:

I am happy for the application to be approved, based on the acoustic consultants findings especially in relation to the 'separating' floor between the shop premises and the residential flats above. Furthermore the hours of operation, as stipulated in the acoustic report, must be adhered to i.e 09:00 - 18:00 Monday to Friday and 09:00 to 19:00 Friday and Saturday. As stated "the venue will not be open during noise sensitive hours and will not cause any sleep disturbance". The agreed construction of a lobby area will assist in preventing noise overspill to the public walkway area outside the front of the premises, and should be written into any approval.

If you need to discuss any of the above, please do not hesitate to contact me.

Kind regards

Mark Moss
Senior Environmental Health Officer
Environmental Health
Havant Borough Council
Tel: 02392 - 446666 or Admin support: 02392-446670