



Martin Critchley
Chartered Architect

7 North Street, Havant,
Hampshire, PO9 1PW

Tel: 023 92 474 919
Fax: 023 92 499 933

critchleyarchitect@hotmail.com

Ref:- MHC/mw/1328

www.critchleyarchitect.com

Adult Learning Centre, Havant Sixth Form College. Preliminary Tree Survey & Method Statement

Tree Schedule to BS.5837:2012.

Ref	Species	Ht	Trunk	Spread	Age	Form	Comment	Cat
1	Laburnum <i>Laburnum alpinum</i>	10	450	N5 E5 S5 W5	MA	Good	Well formed	B2
2	Cedar <i>Cedrus atlantica</i>	12	340	N4 E3 S3 W5	Y	Fair	Offset from T.5. .	B3
3	Larch <i>Larix deodrus</i>	10	230 E-	N2 S2 W3	Y	Poor	Offset from T.5. .	B3
4	Maple <i>Acer campsetre</i>	7	160	N2.5 E2.5 S2 W2.6	Y	Good	Uncertain future near T.5	B2
5	Eucalyptus <i>Eucalyptus dairympleana</i>	17	950	N8 E8 S8 W8	MA	Good	Well formed Landscape value	A2

1.0 Assessment of Tree Constraints.

- 1.1 Of the trees in the vicinity of the site, only T.5. is the dominant feature.
- 1.2 It is not intended to remove any of the trees as part of the proposals.
- 1.3 T.3. is a poor specimen, dominated by T.5. and is likely to be removed in the near future.

- 1.4 Physical protection measures will be required to T.1. and T.2. during the construction process.
- 1.5 The root protection zone for T.1, and T.2. extends to the proposed construction area and special measures will be required.

2.0 Phasing of Operations

- 2.1 Pre- Development.
Instruct contractors on the importance of tree protection measures.
Set out protection zones.
- 2.2 Tree Protection Measures.
Erect protective fences to T.1. and T.2. in accordance with BS. 5837:2012.
- 2.3 Demolition Works.
Locate debris skips away from protection zones.
Keep demolition vehicles to existing drive areas.
Locate bonfires well away from all trees.
- 2.4 Construction Works.
Instruct contractors on the importance of tree protection measures.
Keep delivery vehicles to existing drive areas.
Keep materials stockpiles away from tree protection areas.
Foundations and reduced levels within tree protection areas to be hand dug.
Proposed footpaths to have flexible paved ground covering.
Provide ground protection to scaffolding within protection zones.

3.0 Service Trenches

- 3.1 No new service trenches are required within the tree protection areas.

Martin Critchley, Chartered Architect.

7, North Street, Havant,
Hampshire, PO9 1PW

25th July 2013