



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Southern House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

APP/13/01018

Our Ref

PLAN-005014

Date

06/01/2014

Dear Sir

Proposal: Proposal: Discharge of Conditions No's 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 16, 17, 18, 26, 30, 31, 32, 33, 35, 36, 38, 43 and 46 of Planning Permission APP/13/00103.

Site: Land adjacent to A3M and West of, Brooklands Road, Havant PO9 3JZ. APP/13/01018

We regret Southern Water cannot recommend discharge of condition as the proposed foul drainage layout is unacceptable to Southern Water.

Please note: The foul sewer should be a minimum of 3 metres from the top of the detention basin side slopes.

The Council's Building Control officers/technical staff and the environment agency should be consulted regarding the discharge condition for surface water disposal.

Yours sincerely


Developer Services