

Denise Sheath

From: Heather Lealan
Sent: 26 November 2012 14:02
To: bst shared
Subject: FW: Consultations Response for Goldring Close APP/12/00966

Please redact as necessary and import to Meridio of Drainage Engineer consultee response

Heather Lealan
Planning Officer
Development Control
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hants
PO9 2AX

Direct dial telephone number: 023 9244 6523
Email address: heather.lealan@havant.gov.uk
www.havant.gov.uk

From: Steve Mountain
Sent: 26 November 2012 12:18
To: Heather Lealan
Subject: RE: Consultations Response for Goldring Close APP/12/00966

If it is for access only, then my comment would be that in forming the access, no ditch is to be culverted, diverted or filled in without the express consent of Hampshire County Council.

Best wishes

Steve Mountain
Special Projects Engineer
Transport & Implementation Team
Environment & Neighbourhood Quality
Havant Borough Council
Southmoor Offices and Depot, 2 Penner Road, Havant, PO9 1QH
[\[Location Map\]](#) [\[Get here by bike \(journey planner\)\]](#) [\[Get here by bus \(journey planner\)\]](#)
[\[For a more sociable way of travelling, why not Car Share?\]](#)

Telephone: 023 9244 6444
Fax: 023 9249 8031
HBC on the web: www.havant.gov.uk

From: Heather Lealan
Sent: 26 November 2012 12:11
To: Steve Mountain
Subject: RE: Consultations Response for Goldring Close APP/12/00966

Thanks Steve,

Yes it is outline, for access only. As such does the email below complete your consultation response for this outline stage?

regards Heather

Heather Lealan
Planning Officer
Development Control
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hants
PO9 2AX

Direct dial telephone number: 023 9244 6523
Email address: heather.lealan@havant.gov.uk
www.havant.gov.uk

From: Steve Mountain
Sent: 26 November 2012 12:07
To: Heather Lealan
Subject: RE: Consultations Response for Goldring Close APP/12/00966

I only had something from Louise Gilbertson forwarded to me on the 25/10 from what I recall. Is it outline? In which case the FRA supplied is OK, it does recognise that a lot of further work is required in order to prove any SUDs design.

Best wishes

Steve Mountain
Special Projects Engineer
Transport & Implementation Team
Environment & Neighbourhood Quality
Havant Borough Council
Southmoor Offices and Depot, 2 Penner Road, Havant, PO9 1QH
[\[Location Map\]](#) [\[Get here by bike \(journey planner\)\]](#) [\[Get here by bus \(journey planner\)\]](#)
[\[For a more sociable way of travelling, why not Car Share?\]](#)

Telephone: 023 9244 6444
Fax: 023 9249 8031
HBC on the web: www.havant.gov.uk

From: Heather Lealan
Sent: 26 November 2012 12:01
To: Steve Mountain
Subject: Consultations Response for Goldring Close APP/12/00966
Importance: High

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]