

From: Michael Smith
Sent: 18 November 2013 11:53
To: Sally Smith DC
Cc: Katherine Hodges; Jonathan Driver
Subject: RE: Acolaid Case APP/13/00958

Sally,

I have had a look at this application from a nuisance point of view. My colleagues in the Commercial Team have no adverse comments. I understand that this application is only to regularise the activity taking place on site already. From what I can see the site is fairly far away from residential properties, and we have not received any complaints about noise, lighting etc. I would however request that there is a condition relating to noise levels from the installation of any plant/machinery etc:

Condition 1:

Any proposal relating to install noise making equipment (i.e. refrigeration units, air conditioning, extract ventilation equipments, pumping equipment) schemes shall be agreed and approved in writing by the District Planning Authority prior any development takes place.

BS4142 Requirement

Noise resulting from the use of any/all plant, machinery or equipment shall not exceed a level of 5dB(A) below the existing background level (or 10dB(A) below if there is a particular tonal quality) when measured according to British Standard BS4142-1997.

Thanks and Regards...Mike

Mike Smith
Environmental Health
Havant Borough Council
Ground Floor - Block A
Public Service Plaza | Civic Centre Road | Havant | PO9 2AX
Ext: 446678
Email: michael.smith@havant.gov.uk