

Havant Borough Council

The Town and Country Planning Act 1990

Consultation on Planning Application

To
From : Executive Head of Planning and Built Environment

From
To: Building Control

DC Case Officer Mrs H Lealan Ext: 9244 6523

Date: 04 September 2013

Application No. APP/13/00841

Site Address: 28 Lodge Road, Havant, PO9 3LL

Proposed Development: Demolition of existing house and erection of a replacement 4 bed house with detached garage and a 2 bed bungalow.

I attach a copy of the above application that has been received under the Town and Country Planning Acts.

Any views you should wish to make should be returned to me together with the application papers no later than 18 September 2013.

C. D. Murray

Mr Chris Murray
Service Manager (Planning Development)

From: Building Control

The application has been examined under the following areas where Building Regulations may impact on the planning application. In achieving Building Regulation compliance there may be a number of design solutions available and until a Building Regulations submission has been made it is not always possible to advise what, if any, changes may be required to the design.

The following areas have been considered:

Fire Brigade Access | ① Solid Waste Storage | ② Glazing (Positions, quantities, cleaning) | ✓

Siting of building/structure | ✓ Building over public sewers | ✓ Flues | ✓ Other | ✓

Please note no observations have been made in respect of disabled access. The DC Case Officer should discuss any access concerns with Building Control at the Access Surgery following assessment of the scheme using the access check sheet.

Observations:

- ① Access route to comply with AD B section 5 re fire vehicle
② Bus to be moved to agreed collection point on day of collection

Signed: CA

Dated: CA