HIGHWAYS

PLANNING APPLICATION OBSERVATIONS

APPLICATION NO: APP/11/00304 SENT DATE: 05 April 2011

SITE ADDRESS :34 Wittering Road, Hayling Island, PO11 9SP

PROPOSED DEVELOPMENT: Two storey extension to south west elevation; two storey extension to north east and north west elevations and additional accommodation at second storey level including terrace.

CONTRIBUTION REQUIRED FLOORSPACE.....

CALCULATION.....House hold extention N/A.....

.....

.....

REFUSE REASONS FOR REFUSAL.....

.....

DEFER REASONS FOR DEFERMENT.....The garage is of insufficent depth the internal measurement is only 4.8m which will not allow for the doors to be closed On a lot of cars dose not meet HBC standard

---

APPROVE SUBJECT TO CONDITIONS FOLLOWING CONDITIONS TO APPLY

1).....

2).....

3).....

4).....

INFORMATION TO BE ADDED TO DECISION NOTICE

Dropped Kerb.....Section 38.....Section 278.....

.....

SECTION 106 REQUIRED.....

.....

GENERAL COMMENTS:.....

Highway Engineer Tracy Mc Ford Initial TJF Date 19/04/2011